

Addendum 03

DATED: 6/18/2020

PROJECT : ERCA - JRPH Heritage Centre

PROJECT NO. : 2020

OWNER : Essex Region Conservation Authority (ERCA)

This addendum forms part of the Contract Documents and amends the original drawings and specifications as noted below

ELECTRICAL: Reference drawing E301 - **ELECTRICAL KEYNOTES LEGEND**

Note: E013 - PROVIDE 100A SAFETY DISCONNECT SWITCH WITH 70A FUSES, 600V, 3P, 3 FUSES,4W, TYPE 1. MODEL NO. HFC363. BRAND: SIEMENS OR APPROVED EQUIVALENT.

1. This should read: E013 - PROVIDE 200A SAFETY DISCONNECT SWITCH WITH 125A FUSES, 600V, 3P, 3 FUSES,4W, TYPE 1. BRAND: SIEMENS OR APPROVED EQUIVALENT.

End of Addendum 03

Per : Bill Churchill